

Certificate of Approval

Certificate No.: SAA120317

Date of Issue: 29 February 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder: Jiangsu Goodwe Power Supply Technology Co., Ltd.

No. 189, Kunlunshan Road, Science Town, Hi-tech

Zone, Suzhou City, Jiangsu Province

P.R. China

Class Description: Non-Declared

Product Description: Grid-tied PV Inverter

Brand Name: Goodwe
Model No.: GW4600-DS

Markings: Input: 125-580Vdc MPPT: 125-550Vdc

2x15A, Max 5400W Class I IP65

Output: 230Vac 50Hz 25A 4.6kW **Standard:** AS 4777.2:2005

Standard: AS 4777.2:2005 AS 4777.3:2005

AS/NZS 3100:2009

Conditions: Nil

Approval Mark: SAA120317

Date First Registered: 29 February 2012

Date of Expiry: 1 March 2017

For and on Behalf of SAA Approvals Pty Ltd



