

Certificate G59/2

Engineering Recommendation

Manufacturer: Jiangsu GoodWe Power Supply Technology Co.,Ltd.
Address: NO.189 Kun Lun Shan Road, Suzhou New District, Jiangsu
Tel: +86 512 6239 7998
Fax: +86 512 6239 7972
Post Code: 215163
Country: China

Test house details: Jiangsu GoodWe Power Supply Technology Co.,Ltd.
R&D Department
Email: service@goodwe.com.cn


Type reference: GoodWe String Inverters GW4000-SS, GW4600-SS
Max AC power: 4400W / 5100W
Nominal AC power: 4000W / 4600W

The results of the G59/2 tests are summarized in this certificate. GoodWe declares hereby that all units shipped to the UK comply with the specifications and parameters defined in the G59/2 engineering recommendation. These settings cannot be changed by installer, user or by anyone other than GoodWe. Complete documentation on test details are available at GoodWe on demand.

Test details

- Harmonic current emissions according to BS EN 61000-3-12
- Voltage fluctuations and flicker according to BS EN 61000-3-11
- DC Injection / Power Factor
- Under / Over frequency tests
- Under / Over voltage tests
- Loss of mains test
- Reconnection time

Jiangsu GoodWe Power Supply Technology Co.,Ltd.
Suzhou, 11/12/2011


Zhang Kun

Manager of Technical Support Department